



(Division of Acme Mfg. Corp.)
6532 Tower Lane
Claremore, OK 74019

(800) 647-8671 Toll Free
(918) 266-3091 Fax

FILTERGUARD PANELS INSTALLATION AND MAINTENANCE

If Filterguard Panels are to be stored prior to installation, they must be stored in a clean dry location. When installed the heating element should be terminated into a waterproof enclosure immediately or protected from the elements.

-Avoid Re-bending or twisting cables at any brazed joint in the cable.

-Install Filterguard Panels with heating element facing air flow.

Mistop Filterguard Panels require minimal maintenance.

Visual inspection is recommended if there is potential of clogging with dirt or foreign substance.

If clogging occurs, remove Filterguard Panels and flush with steam or water. Flushing should not have sufficient force to dislodge media panels or heat trace cables.